Water and Sanitation Certificates

Regd

CHIEF MEDICAL AND HEALTH OFFICE
JAIPUR FIRST
MINI SWASTHYA BHAWAN SETHI COLONY JAIPUR

APPENDIX-VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dis.No. 1358 Date 09/06/25

It is certified that an inspection team headed by **Dr. Ravi Shekhawat CM&HO Jaipur I** from **Chief Medical & Health office Jaipur First** inspected the **Praband samithi adarsh Vidhya Mandir Adarsh Nagar Jaipur** on 06-06-2025 and found that the **Praband samithi adarsh Vidhya Mandir Adarsh Nagar Jaipur** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central / State /U.T Govt.

The above valid for a period of **One Year to issue date**

Signature with Seal:----------

Name **Dr. Ravi Shekhawat**

Designation CM&HO JAIPUR FIRST

To

Praband samithi
adarsh Vidhya Mandir
Adarsh Nagar Jaipur

Self attested

PRINCIPAL
Adarsh Vidhya Mandir (CBSE)
Near Dashehara Ground
Adarsh Nagar, JAIPUR-302004

Scanned with OKEN Scanner

Scanned with OKEN Scanner

Water Sample test Report from Public Health Engineer Department.

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2025-2026/ 718 Date: 2/6/25

To,
Principal
Senior Secondary Adarsh Vidhya Mandir Adarsh Nagar,
Jaipur.

Date of Receipt-28.05.25

The Sample was not Collected by this Laboratory

Particulars	value as per I.S.:10500/2012		RO Water Adarsh Vidhya Mandir Adarsh Nagar
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			28.05.2025
Lab. Sample No.			P-45
1. pH	6.5-8.5	6.5-8.5	6.98
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	70
6. Total Hardness (as CaCo3) mg/l	200	600	40
7. Calcium (as Ca) mg/l	75	200	8
8. Magnesium (as Mg) mg/l	30	100	5
9. Chloride (as Cl-) mg/l	250	1000	20
10. Nitrates (as NO3-) mg/l	45	45	1
11.Sulphate(as So4-2)mg/l	200	400	2
12. Total Dissolved Solids mg/l	500	2000	112
13.Fluoride mg/l	1.00	1.5	0.11
14.Iron mg/l	1.0	No Relexation	Nil
15.Arsenic mg/l	0.01	No Relexation	Nil

Remark- 1. All chemical parameters except pH are in mg/l
2.Tested Results Relate only to The Samples send by you

02/06/25
Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2025-2026/ Date:
Copy to:- 1.The Chief Chemist, PHED Raj. Jaipur

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

Scanned with OKEN Scanner
Scanned with OKEN Scanner
Scanned with OKEN Scanner