

**CHIEF MEDICAL AND HEALTH OFFICE
JAIPUR FIRST
MINI SWASTHYA BHAWAN SETHI COLONY JAIPUR**

APPENDIX-VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

Dis.No. 1358

Date 09/06/25

It is certified that an inspection team headed by **Dr. Ravi Shekhawat CM&HO Jaipur I** from Chief Medical & Health office Jaipur First inspected the Praband samithi adarsh Vidhya Mandir Adarsh Nagar Jaipur on 06-06-2025 and found that the Praband samithi adarsh Vidhya Mandir Adarsh Nagar Jaipur has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central / State / U.T Govt.

The above valid for a period of **One Year** to issue date

Signature with Seal: _____

Name **Dr. Ravi Shekhawat**

Designation **CM&HO JAIPUR FIRST**

To

**Praband samithi
adarsh Vidhya Mandir
Adarsh Nagar Jaipur**

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2025-2026/ 778

Date: 26/25

To,
Principal
Senior Secondary Adarsh Vidhya Mandir Adarsh Nagar,
Jaipur.

The Sample was not Collected
by this Laboratory

Date of Receipt-28.05.25

Particulars			RO Water Adarsh Vidhya Mandir Adarsh Nagar
	value as per I.S.:10500/2012		
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			28.05.2025
Lab. Sample No.			P-45
1. pH	6.5-8.5	6.5-8.5	6.98
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	70
6. Total Hardness (as CaCo3) mg/l	200	600	40
7. Calcium (as Ca) mg/l	75	200	8
8. Magnesium (as Mg) mg/l	30	100	5
9. Chloride (as Cl-) mg/l	250	1000	20
10. Nitrates (as NO3-) mg/l	45	45	1
11.Sulphate(as So4- 2)mg/l	200	400	2
12. Total Dissolved Solids mg/l	500	2000	112
13.Fluoride mg/l	1.00	1.5	0.11
14.Iron mg/l	1.0	No Relaxtion	Nil
15.Arsenic mg/l	0.01	No Relaxtion	Nil

Remark- 1. All chemical parameters except pH are in mg/l
2. Tested Results Relate only to The Samples send by you

26/06/25
Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2025-2026/
Copy to:- 1. The Chief Chemist, PHED Raj. Jaipur

Date:

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur